

Mulwala Water Filtration Plant

EPA Licence Number: 841

Licence web link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33662&SYSUID=1&LICID=841>

Licencee: Federation Council

Sampling Frequency: Monthly

Effluent - Point 1

Description	BOD	pH	Total Suspended Solids
Concentration Limit	none	none	50
Units	mg/L	pH Units	mg/L
Sample Date			
02-Jan-13	<2	7.1	2
23-Jan-13	<2	7.1	4
20-Feb-13	<2	7.2	6
20-Mar-13	<2	7.1	5
17-Apr-13	<2	7.0	<2
15-May-13	<2	7.1	<2
12-Jun-13	2.0	7.1	<2
10-Jul-13	<2	6.8	<2
07-Aug-13	3.0	6.7	10
04-Sep-13	<2	7.1	<2
02-Oct-13	<2	7.0	<2
30-Oct-13	3.0	7.0	<2
27-Nov-13	<2	6.8	<2
18-Dec-13	4.0	6.8	<2
22-Jan-14	<2	7.0	2
19-Feb-14	<2	6.9	15
19-Mar-14	4.0		66
16-Apr-14	<2		4
14-May-14	<2		3
11-Jun-14	<2		4
09-Jul-14	<2	6.8	44
06-Aug-14	<2		4
03-Sep-14	3.0		16
01-Oct-14	<2		14
29-Oct-14	<2		10
26-Nov-14	<2		5
07-Jan-15	<2		<2
04-Feb-15	<2		4
04-Mar-15	<2		4
01-Apr-15	<2		3
29-Apr-15	<2		4
27-May-15	2.0		4
24-Jun-15	<2		<2
22-Jul-15	3.0	7.1	<2
19-Aug-15	<2	7.5	8
16-Sep-15	3.0		4
14-Oct-15	3.0	6.6	<2
11-Nov-15	2.0	6.7	4
09-Dec-15	2.0	6.8	2
06-Jan-16	<2	6.8	4
03-Feb-16	2.0	7.0	2
02-Mar-16	<2	7.0	8
30-Mar-16	<2	6.9	3
27-Apr-16	<2	6.6	10
25-May-16	<2	6.9	<2
22-Jun-16	<2	6.6	6
20-Jul-16	<2	7.1	3
17-Aug-16	<2	6.7	4
14-Sep-16	<2	6.7	<2
12-Oct-16	<2	7.0	13

Mulwala Water Filtration Plant

EPA Licence Number: 841

Licence web link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33662&SYSUID=1&LICID=841>

Licencee: Federation Council

Sampling Frequency: Monthly

Effluent - Point 1

Description	BOD	pH	Total Suspended Solids
Concentration Limit	none	none	50
Units	mg/L	pH Units	mg/L
Sample Date			
09-Nov-16	<2	7.0	29
07-Dec-16	<2	7.0	4
04-Jan-17	<2	6.7	5
01-Feb-17	<2	6.8	4
01-Mar-17	<2	7.0	5
29-Mar-17	<2	6.9	3
26-Apr-17	<2	7.1	10
24-May-17	<2	7.2	<3
21-Jun-17	<2	7.1	<3
19-Jul-17	<2	7.0	4
16-Aug-17	<2	7.1	<3
13-Sep-17	<2	6.8	<3
11-Oct-17	3.0	6.9	<3
08-Nov-17	<2	7.2	3
06-Dec-17	<2	6.9	3
03-Jan-18	<2	6.7	5
31-Jan-18	<2	7.0	<3
28-Feb-18	3.0	7.0	3
28-Mar-18	6.0	7.0	<3
26-Apr-18	<2	6.7	<3
23-May-18	6.0	6.8	<3
20-Jun-18	<2	6.7	<3
18-Jul-18	<2	6.6	3
15-Aug-18	<2	6.6	<3
12-Sep-18	5.0	6.7	<3
10-Oct-18	5.0	6.7	3
07-Nov-18	<2	6.5	3
05-Dec-18	2.0	6.7	4
30-Jan-19	<2	6.5	<3
27-Feb-19	<2	6.8	<3
27-Mar-19	<2	7.0	3
23-Apr-19	<2	6.9	10
22-May-19	<2	6.8	<3
19-Jun-19	<2	6.6	<3
17-Jul-19	<2	6.6	4
14-Aug-19	2.0	7.2	4
11-Sep-19	2.0	6.6	<3
09-Oct-19	<2	6.9	<3
06-Nov-19	<2	6.77	<3
04-Dec-19	<2	4.6	5
08-Jan-20	3.0	6.7	<3
05-Feb-20	<2	7.3	3
04-Mar-20	<2	7.0	6
01-Apr-20	<2	6.5	<3
06-May-20	<2	6.7	<3
03-Jun-20	<2	6.8	5
01-Jul-20	<2	6.6	<3
05-Aug-20	<2	6.7	5
02-Sep-20	2.0	6.6	<3
07-Oct-20	<2	6.3	<3

Mulwala Water Filtration Plant

EPA Licence Number: 841

Licence web link: <http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=33662&SYSUID=1&LICID=841>

Licencee: Federation Council

Sampling Frequency: Monthly

Effluent - Point 1

Description	BOD	pH	Total Suspended Solids
Concentration Limit	none	none	50
Units	mg/L	pH Units	mg/L
Sample Date			
04-Nov-20	<2	6.6	5
02-Dec-20	2.0	7.0	4
06-Jan-21	<2	6.6	10
03-Feb-21	<2	6.6	10
03-Mar-21	<2	6.6	7
07-Apr-21	4.0	6.7	<3
05-May-21	4.0	6.1	<3
01-Jun-21	<2	7.9	<3
07-Jul-21	<2	6.5	<3
04-Aug-21	2.0	6.7	4
01-Sep-21	<2	6.5	<3
06-Oct-21	<2	6.6	<3
03-Nov-21	<2	6.8	<3
01-Dec-21	3.0	6.7	3
05-Jan-21	<2	6.8	3
02-Feb-22	3.0	6.9	4
02-Mar-22	<2	6.8	<3
06-Apr-22	<2	6.8	<3
04-May-22	<2	6.8	<3
01-Jun-22	<2	6.8	<3
06-Jul-22	<2	6.7	<3
03-Aug-22	<2	7.0	<3
31-Aug-22	<2	6.6	<3
05-Oct-22	2.0	6.8	<3
02-Nov-22	<2	6.8	<3
06-Dec-22	<2	6.8	<3
11-Jan-23	<2	6.6	4
01-Feb-23	<2	6.7	5
01-Mar-23	<2	7.3	6
05-Apr-23	<2	6.5	<3
02-May-23	<2	6.6	<3
07-Jun-23	<2	6.4	<3
5-Jul-23	<2	6.5	<3
02-Aug-23	<2	6.6	<3
06-Sep-23	<2	6.5	<3
04-Oct-23	<2	6.6	<3
01-Nov-23	<2	6.7	<3
06-Dec-23	<2	5.9	<3
03-Jan-24	<2	7.0	4
07-Feb-24	<2	7.1	3
05-Mar-24	<2	6.9	<3
03-Apr-24	<2	6.9	<3
01-May-24	<2	6.9	20
05-Jun-24	<2	6.8	6
03-Jul-24	<2	6.8	<3
07-Aug-24	<2	6.8	5
04-Sep-24	<2	6.8	<3
02-Oct-24	<2	6.9	3
06-Nov-24	<2	6.4	6
03-Dec-24	<2	6.8	3

