

# Water Quality Summary Reports - Mulwala

NSW Drinking Water Monitoring Program

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
<b>November 2024</b>													
Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)												
	Fluoride Ratio												
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7733	0.8100	0.1193	0.64	0.87	3	0	0.87	0.64	100.00
	pH	6.5 - 8.5		7.2433	7.2400	0.0153	7.23	7.26	3	0	7.26	7.23	100.00
	Temperature	30.0000	C	21.7667	21.6000	0.8622	21	22.7	3	0	22.7	21	100.00
	Total Chlorine	5.0000	mg/L	0.9000	0.9400	0.1345	0.75	1.01	3	0	1.01	0.75	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2167	0.2100	0.0306	0.19	0.25	3	0	0.25	0.19	100.00
<b>October 2024</b>													
Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)												
	Fluoride Ratio												
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	6	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7183	0.7900	0.1622	0.45	0.86	6	0	0.86	0.45	100.00
	pH	6.5 - 8.5		7.3100	7.3500	0.1562	7.08	7.52	6	0	7.52	7.08	100.00
	Temperature	30.0000	C	19.3333	19.4500	1.5513	17	21.2	6	0	21.2	17	100.00
	Total Chlorine	5.0000	mg/L	0.8383	0.9200	0.1785	0.54	0.99	6	0	0.99	0.54	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	6	0	0	0	100.00
	Turbidity	5.0000	NTU	0.3000	0.1800	0.3046	0.14	0.92	6	0	0.92	0.14	100.00
<b>September 2024</b>													
Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)												
	Fluoride Ratio												
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.8375	0.8200	0.0427	0.81	0.9	4	0	0.9	0.81	100.00
	pH	6.5 - 8.5		7.2100	7.2100	0.0577	7.14	7.28	4	0	7.28	7.14	100.00
	Temperature	30.0000	C	17.2000	17.1500	0.7071	16.4	18.1	4	0	18.1	16.4	100.00
	Total Chlorine	5.0000	mg/L	0.9800	0.9750	0.0374	0.94	1.03	4	0	1.03	0.94	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1775	0.1700	0.0340	0.15	0.22	4	0	0.22	0.15	100.00
<b>August 2024</b>													
Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L										
	Fluoride Ratio	0.8 - 1.2											
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.8575	0.8800	0.0670	0.76	0.91	4	0	0.91	0.76	100.00
	pH	6.5 - 8.5		7.1350	7.1100	0.0645	7.09	7.23	4	0	7.23	7.09	100.00
	Temperature	30.0000	C	16.0000	15.9000	2.0445	13.6	18.6	4	0	18.6	13.6	100.00
	Total Chlorine	5.0000	mg/L	0.9900	1.0200	0.0600	0.9	1.02	4	0	1.02	0.9	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1575	0.1500	0.0222	0.14	0.19	4	0	0.19	0.14	100.00
<b>July 2024</b>													
Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7800	0.7850	0.0648	0.7	0.85	4	0	0.85	0.7	100.00

# Water Quality Summary Reports - Mulwala

NSW Drinking Water Monitoring Program

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
	pH	6.5 - 8.5		7.1925	7.2300	0.1360	7	7.31	4	0	7.31	7	100.00
	Temperature	30.0000	C	14.3500	13.9000	1.3528	13.3	16.3	4	0	16.3	13.3	100.00
	Total Chlorine	5.0000	mg/L	0.8800	0.8650	0.0716	0.81	0.98	4	0	0.98	0.81	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1550	0.1500	0.0370	0.12	0.2	4	0	0.2	0.12	100.00

## June 2024

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Chemistry	Aluminium	0.2000	mg/L	0.0200	0.0200	0.0000	0.02	0.02	1	0	0.02	0.02	100.00
	Antimony	0.0030	mg/L	0.0001	0.0001	0.0000	0.00005	0.00005	1	0	0.00005	0.00005	100.00
	Arsenic	0.0100	mg/L	0.0005	0.0005	0.0000	0.0005	0.0005	1	0	0.0005	0.0005	100.00
	Barium	2.0000	mg/L	0.0095	0.0095	0.0000	0.0095	0.0095	1	0	0.0095	0.0095	100.00
	Boron	4.0000	mg/L	0.0028	0.0028	0.0000	0.0028	0.0028	1	0	0.0028	0.0028	100.00
	Cadmium	0.0020	mg/L	0.0001	0.0001	0.0000	0.00005	0.00005	1	0	0.00005	0.00005	100.00
	Calcium	###	mg/L	7.2000	7.2000	0.0000	7.2	7.2	1	0	7.2	7.2	100.00
	Chloride	250.0000	mg/L	6.0000	6.0000	0.0000	6	6	1	0	6	6	100.00
	Chromium	0.0500	mg/L	0.0005	0.0005	0.0000	0.0005	0.0005	1	0	0.0005	0.0005	100.00
	Copper	2.0000	mg/L	0.0130	0.0130	0.0000	0.013	0.013	1	0	0.013	0.013	100.00
	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L	0.0600	0.0600	0.0000	0.06	0.06	1	0	0.06	0.06	100.00
	Fluoride Ratio	0.8 - 1.2		0.6000	0.6000	0.0000	0.6	0.6	1	1	0.6	0.6	0.00
	Iodine	0.5000	mg/L	0.0100	0.0100	0.0000	0.01	0.01	1	0	0.01	0.01	100.00
	Iron	0.3000	mg/L	0.0100	0.0100	0.0000	0.01	0.01	1	0	0.01	0.01	100.00
	Lead	0.0100	mg/L	0.0011	0.0011	0.0000	0.0011	0.0011	1	0	0.0011	0.0011	100.00
	Magnesium	###	mg/L	2.3300	2.3300	0.0000	2.33	2.33	1	0	2.33	2.33	100.00
	Manganese	0.5000	mg/L	0.0017	0.0017	0.0000	0.0017	0.0017	1	0	0.0017	0.0017	100.00
	Mercury	0.0010	mg/L	0.0004	0.0004	0.0000	0.0004	0.0004	1	0	0.0004	0.0004	100.00
	Molybdenum	0.0500	mg/L	0.0001	0.0001	0.0000	0.0001	0.0001	1	0	0.0001	0.0001	100.00
	Nickel	0.0200	mg/L	0.0004	0.0004	0.0000	0.0004	0.0004	1	0	0.0004	0.0004	100.00
	Nitrate	50.0000	mg/L	0.5000	0.5000	0.0000	0.5	0.5	1	0	0.5	0.5	100.00
	Nitrite	3.0000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	pH	6.5 - 8.5		7.3000	7.3000	0.0000	7.3	7.3	1	0	7.3	7.3	100.00
	Selenium	0.0100	mg/L	0.0035	0.0035	0.0000	0.0035	0.0035	1	0	0.0035	0.0035	100.00
	Silver	0.1000	mg/L	0.0001	0.0001	0.0000	0.0001	0.0001	1	0	0.0001	0.0001	100.00
	Sodium	180.0000	mg/L	7.0000	7.0000	0.0000	7	7	1	0	7	7	100.00
	Sulfate	500.0000	mg/L	13.0000	13.0000	0.0000	13	13	1	0	13	13	100.00
	Total Dissolved Solids (TDS)	###	mg/L	43.0000	43.0000	0.0000	43	43	1	0	43	43	100.00
	Total Hardness as CaCO3	200.0000	mg/L	27.6000	27.6000	0.0000	27.6	27.6	1	0	27.6	27.6	100.00
	True Colour	15.0000	Hazen	1.0000	1.0000	0.0000	1	1	1	0	1	1	100.00
	Turbidity	5.0000	NTU	0.1000	0.1000	0.0000	0.1	0.1	1	0	0.1	0.1	100.00
	Uranium	0.0170	mg/L	0.0001	0.0001	0.0000	0.00005	0.00005	1	0	0.00005	0.00005	100.00
	Zinc	3.0000	mg/L	0.0200	0.0200	0.0000	0.02	0.02	1	0	0.02	0.02	100.00

## May 2024

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100
	Fluoride (WU result)												
	Fluoride Ratio												
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.8540	0.7800	0.1812	0.65	1.06	5	0	1.06	0.65	100.00
	pH	6.5 - 8.5		7.2840	7.2600	0.0577	7.22	7.35	5	0	7.35	7.22	100.00
	Temperature	30.0000	C	18.1800	18.5000	1.2538	16.5	19.5	5	0	19.5	16.5	100.00
	Total Chlorine	5.0000	mg/L	1.0120	0.9600	0.1956	0.79	1.24	5	0	1.24	0.79	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	5	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1620	0.1500	0.0342	0.13	0.22	5	0	0.22	0.13	100.00

## April 2024

Apr-21	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00

# Water Quality Summary Reports - Mulwala

## NSW Drinking Water Monitoring Program

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Microbiology	Fluoride (WU result)												
	Fluoride Ratio												
	E. coli	0.0000	mpn/100	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.9500	0.9350	0.0735	0.89	1.04	4	0	1.04	0.89	100.00
	pH	6.5 - 8.5		7.1900	7.1850	0.0726	7.11	7.28	4	0	7.28	7.11	100.00
	Temperature	30.0000	C	20.7000	20.2500	1.5384	19.5	22.8	4	0	22.8	19.5	100.00
	Total Chlorine	5.0000	mg/L	1.0725	1.0650	0.0866	0.99	1.17	4	0	1.17	0.99	100.00
	Total Coliforms	0.0000	mpn/100	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.1550	0.1650	0.0238	0.12	0.17	4	0	0.17	0.12	100.00

### March 2024

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	2	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L										
	Fluoride Ratio	0.8 - 1.2		0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
Microbiology	E. coli	0.0000	mpn/100	0.0000	0.8100	0.1060	0.62	0.86	4	0	0.86	0.62	100.00
	Free Chlorine	0.2 - 5	mg/L	0.8933	0.8500	0.1401	0.78	1.05	3	0	1.05	0.78	100.00
	pH	6.5 - 8.5		7.2700	7.2800	0.0265	7.24	7.29	3	0	7.29	7.24	100.00
	Temperature	30.0000	C	23.9333	24.5000	1.3429	22.4	24.9	3	0	24.9	22.4	100.00
	Total Chlorine	5.0000	mg/L	1.0000	0.9500	0.1706	0.86	1.19	3	0	1.19	0.86	100.00
	Total Coliforms	0.0000	mpn/100	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2200	0.1900	0.0794	0.16	0.31	3	0	0.31	0.16	100.00

### February 2024

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	2	0	0.05	0.05	100.00
	Fluoride (WU result)												
	Fluoride Ratio												
Microbiology	E. coli	0.0000	cfu/100	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7750	0.8100	0.1060	0.62	0.86	4	0	0.86	0.62	100.00
	pH	6.5 - 8.5		7.2425	7.2400	0.0538	7.18	7.31	4	0	7.31	7.18	100.00
	Temperature	30.0000	C	24.6750	24.7000	0.6994	23.8	25.5	4	0	25.5	23.8	100.00
	Total Chlorine	5.0000	mg/L	0.9000	0.9300	0.0966	0.76	0.98	4	0	0.98	0.76	100.00
	Total Coliforms	0.0000	cfu/100	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2525	0.2600	0.0299	0.21	0.28	4	0	0.28	0.21	100.00

### January 2024

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Fluoride Barcode	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)												
	Fluoride Ratio												
Microbiology	E. coli	0.0000	mpn/100	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.7250	0.7200	0.2094	0.49	0.97	4	0	0.97	0.49	100.00
	pH	6.5 - 8.5		7.2100	7.2350	0.0949	7.08	7.29	4	0	7.29	7.08	100.00
	Temperature	30.0000	C	24.8000	24.7500	1.0231	23.6	26.1	4	0	26.1	23.6	100.00
	Total Chlorine	5.0000	mg/L	0.8400	0.8350	0.2273	0.58	1.11	4	0	1.11	0.58	100.00
	Total Coliforms	0.0000	mpn/100	0.0000	0.0000	0.0000	0	0	4	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2200	0.2250	0.0245	0.19	0.24	4	0	0.24	0.19	100.00

### December 2024

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
Chemistry	Aluminium	0.2000	mg/L	0.0300	0.0300	0.0000	0.03	0.03	1	0	0.03	0.03	100.00
	Antimony	0.0030	mg/L	0.0001	0.0001	0.0000	0.00005	0.00005	1	0	0.00005	0.00005	100.00
	Arsenic	0.0100	mg/L	0.0005	0.0005	0.0000	0.0005	0.0005	1	0	0.0005	0.0005	100.00
	Barium	2.0000	mg/L	0.0089	0.0089	0.0000	0.0089	0.0089	1	0	0.0089	0.0089	100.00
	Boron	4.0000	mg/L	0.0027	0.0027	0.0000	0.0027	0.0027	1	0	0.0027	0.0027	100.00
	Cadmium	0.0020	mg/L	0.0001	0.0001	0.0000	0.00005	0.00005	1	0	0.00005	0.00005	100.00
	Calcium	###	mg/L	7.5000	7.5000	0.0000	7.5	7.5	1	0	7.5	7.5	100.00
	Chloride	250.0000	mg/L	6.0000	6.0000	0.0000	6	6	1	0	6	6	100.00
	Chromium	0.0500	mg/L	0.0005	0.0005	0.0000	0.0005	0.0005	1	0	0.0005	0.0005	100.00
	Copper	2.0000	mg/L	0.0410	0.0410	0.0000	0.041	0.041	1	0	0.041	0.041	100.00
	Fluoride	1.5000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	Fluoride (WU result)	1.5000	mg/L										
	Fluoride Ratio	0.8 - 1.2											
	Iodine	0.5000	mg/L	0.0100	0.0100	0.0000	0.01	0.01	1	0	0.01	0.01	100.00

# Water Quality Summary Reports - Mulwala

## NSW Drinking Water Monitoring Program

Analysis Type	Characteristic	Guideline Value	Units	Mean	Median	Standard Deviation	Min	Max	Sample Count	Exception Count	95th Percentile	5th Percentile	% meeting guideline values
	Iron	0.3000	mg/L	0.0100	0.0100	0.0000	0.01	0.01	1	0	0.01	0.01	100.00
	Lead	0.0100	mg/L	0.0003	0.0003	0.0000	0.0003	0.0003	1	0	0.0003	0.0003	100.00
	Magnesium	###	mg/L	1.6900	1.6900	0.0000	1.69	1.69	1	0	1.69	1.69	100.00
	Manganese	0.5000	mg/L	0.0023	0.0023	0.0000	0.0023	0.0023	1	0	0.0023	0.0023	100.00
	Mercury	0.0010	mg/L	0.0004	0.0004	0.0000	0.0004	0.0004	1	0	0.0004	0.0004	100.00
	Molybdenum	0.0500	mg/L	0.0001	0.0001	0.0000	0.0001	0.0001	1	0	0.0001	0.0001	100.00
	Nickel	0.0200	mg/L	0.0002	0.0002	0.0000	0.0002	0.0002	1	0	0.0002	0.0002	100.00
	Nitrate	50.0000	mg/L	0.5000	0.5000	0.0000	0.5	0.5	1	0	0.5	0.5	100.00
	Nitrite	3.0000	mg/L	0.0500	0.0500	0.0000	0.05	0.05	1	0	0.05	0.05	100.00
	pH	6.5 - 8.5		7.7000	7.7000	0.0000	7.7	7.7	1	0	7.7	7.7	100.00
	Selenium	0.0100	mg/L	0.0035	0.0035	0.0000	0.0035	0.0035	1	0	0.0035	0.0035	100.00
	Silver	0.1000	mg/L	0.0001	0.0001	0.0000	0.0001	0.0001	1	0	0.0001	0.0001	100.00
	Sodium	180.0000	mg/L	6.0000	6.0000	0.0000	6	6	1	0	6	6	100.00
	Sulfate	500.0000	mg/L	14.0000	14.0000	0.0000	14	14	1	0	14	14	100.00
	Total Dissolved Solids (TDS)	600.0000	mg/L	44.0000	44.0000	0.0000	44	44	1	0	44	44	100.00
	Total Hardness as CaCO3	200.0000	mg/L	25.7000	25.7000	0.0000	25.7	25.7	1	0	25.7	25.7	100.00
	True Colour	15.0000	Hazen Units (HU)	0.5000	0.5000	0.0000	0.5	0.5	1	0	0.5	0.5	100.00
	Turbidity	5.0000	NTU	0.3000	0.3000	0.0000	0.3	0.3	1	0	0.3	0.3	100.00
	Uranium	0.0170	mg/L	0.0001	0.0001	0.0000	0.00005	0.00005	1	0	0.00005	0.00005	100.00
	Zinc	3.0000	mg/L	0.0200	0.0200	0.0000	0.02	0.02	1	0	0.02	0.02	100.00
Microbiology	E. coli	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Free Chlorine	0.2 - 5	mg/L	0.6667	0.6100	0.1818	0.52	0.87	3	0	0.87	0.52	100.00
	pH	6.5 - 8.5		7.3633	7.4200	0.1159	7.23	7.44	3	0	7.44	7.23	100.00
	Temperature	30.0000	C	23.7333	22.9000	1.4434	22.9	25.4	3	0	25.4	22.9	100.00
	Total Chlorine	5.0000	mg/L	0.7500	0.7200	0.1473	0.62	0.91	3	0	0.91	0.62	100.00
	Total Coliforms	0.0000	mpn/100 mL	0.0000	0.0000	0.0000	0	0	3	0	0	0	100.00
	Turbidity	5.0000	NTU	0.2133	0.1800	0.0850	0.15	0.31	3	0	0.31	0.15	100.00